

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-694:223 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 370-4194

DESIGN: Model P243OK-FC horn/strobe. Suitable for extended indoor operating temperature range of 32° F to 150° F and a NEMA 3R enclosure rating. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Voltage: 20 - 30 VDC
Candela: 30 cd

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as horn strobes suitable for the hearing impaired application when used with separately listed compatible fire alarm control units. For indoor use and wall mount only.

This unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

XLF: 7125-1209:182

12-28-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MAY 23, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy
Program Manager**